



NOTES:
 A - FOR SINGLE COIL SEE GLYCOL PREHEAT SYSTEM.
 B - START CURCULATION PUMP WHEN OUTDOOR AIR TEMPERATURE FALLS BELOW 50F.

100% OUTSIDE AIR POINT IDENTIFICATION

SCALE: NTS