



NOTES:

1. BRACKETS ARE SIZED FOR 12 FEET OF DUCT, MAXIMUM.
2. LOCATE DUCTS AGAINST WALL OR MAXIMUM OF 2" AWAY FROM WALL.
3. EACH WALL ANCHOR SHALL SATISFY THE FOLLOWING CRITERIA UNLESS OTHER ANALYSIS IS MADE:
 - A - TENSILE LOAD = $\frac{3}{8}$ "xDUCT WEIGHT; SAFETY FACTOR OF 4.
 - B - SHEAR LOADx $\frac{1}{2}$ "xDUCT WEIGHT; SAFETY FACTOR OF 4.
4. HANGERS SHALL BE GALVANIZED STEEL

HANGER SUPPORTS FROM WALL

SCALE: NTS